

PFAS Sample Results for Warrington EP 102 - Well #3		
Entry Point 102 - Well #3	Sample Date	Sample Date
	Mar 14, 2023	Apr 18, 2023
Contaminant	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	ND	ND
Perfluoroundecanoic acid (PFUnA)	ND	ND
Perfluorohexanoic acid (PFHxA)	ND	ND
Perfluorododecanoic acid (PFDoA)	ND	ND
Perfluorooctanoic acid (PFOA)	ND	ND
Perfluorodecanoic acid (PFDA)	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	ND	ND
Perfluorobutanesulfonic acid (PFBS)	ND	ND
Perfluoroheptanoic acid (PFHpA)	ND	ND
Perfluorononanoic acid (PFNA)	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND
Perfluorotridecanoic acid (PFTrDA)	ND	ND

PFAS Sample Results for Warrington Well 3 Raw Water			
Well #3 - Raw	Sample Date	Sample Date	Sample Date
	Oct 27, 2020	Mar 14, 2023	Apr 18, 2023
Contaminant	Result (ppt)	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	33	31	30
Perfluoroundecanoic acid (PFUnA)	ND	ND	ND
Perfluorohexanoic acid (PFHxA)	8.2	8.1	7.7
Perfluorododecanoic acid (PFDoA)	ND	ND	ND
Perfluorooctanoic acid (PFOA)	23	30	29.0
Perfluorodecanoic acid (PFDA)	ND	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	15.0	14	14.0
Perfluorobutanesulfonic acid (PFBS)	6.8	7.1	6.4
Perfluoroheptanoic acid (PFHpA)	4.8	5.2	5.0
Perfluorononanoic acid (PFNA)	ND	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND	ND

Perfluorotridecanoic acid (PFTrDA)	ND	ND	ND
------------------------------------	----	----	----

PFAS Sample Results from Midpoint for EP 102		
Midpoint Well #3	Sample Date	Sample Date
	Mar 14, 2023	Apr 18, 2023
Contaminant	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	ND	ND
Perfluoroundecanoic acid (PFUnA)	ND	ND
Perfluorohexanoic acid (PFHxA)	ND	ND
Perfluorododecanoic acid (PFDoA)	ND	ND
Perfluorooctanoic acid (PFOA)	ND	ND
Perfluorodecanoic acid (PFDA)	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	ND	ND
Perfluorobutanesulfonic acid (PFBS)	ND	ND
Perfluoroheptanoic acid (PFHpA)	ND	ND
Perfluorononanoic acid (PFNA)	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND
Perfluorotridecanoic acid (PFTrDA)	ND	ND