

PFAS Sample Results for Warrington EP 102 - Well #3				
Entry Point 102 - Well #3	Sample Date	Sample Date	Sample Date	Sample Date
	Mar 14, 2023	Apr 18, 2023	Nov 16, 2023	Feb 15, 2024
Contaminant	Result (ppt)	Result (ppt)	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	ND	ND	ND	ND
Perfluorohexanoic acid (PFHxA)	ND	ND	ND	ND
Perfluorododecanoic acid (PFDoA)	ND	ND	ND	ND
Perfluorooctanoic acid (PFOA)	ND	ND	ND	ND
Perfluorodecanoic acid (PFDA)	ND	ND	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	ND	ND	ND	ND
Perfluorobutanesulfonic acid (PFBS)	ND	ND	ND	ND
Perfluoroheptanoic acid (PFHpA)	ND	ND	ND	ND
Perfluorononanoic acid (PFNA)	ND	ND	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND	ND	ND
Perfluorotridecanoic acid (PFTrDA)	ND	ND	ND	ND

**Important Note:**

Warrington Well 3 went offline due to mechanical issues during the second quarter of 2024. Since then, it has not been producing water into the system nor has it been functional enough to collect samples from. For more information, please call the NWWA Bucks Office and ask to speak with someone in Water Quality.

PFAS Sample Results from Midpoint for EP 102				
Well #3 - Midpoint	Sample Date	Sample Date	Sample Date	Sample Date
	Mar 14, 2023	Apr 18, 2023	Nov 16, 2023	Feb 15, 2024
Contaminant	Result (ppt)	Result (ppt)	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	ND	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	ND	ND	ND	ND
Perfluorohexanoic acid (PFHxA)	ND	ND	ND	ND
Perfluorododecanoic acid (PFDoA)	ND	ND	ND	ND
Perfluorooctanoic acid (PFOA)	ND	ND	ND	ND
Perfluorodecanoic acid (PFDA)	ND	ND	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	ND	ND	ND	ND
Perfluorobutanesulfonic acid (PFBS)	ND	ND	ND	ND
Perfluoroheptanoic acid (PFHpA)	ND	ND	ND	ND
Perfluorononanoic acid (PFNA)	ND	ND	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND	ND	ND
Perfluorotridecanoic acid (PFTrDA)	ND	ND	ND	ND

ND = Non-Detect, <2.0 ppt

PFAS Sample Results for Warrington Well #3 Raw Water				
Well #3 - Raw	Sample Date	Sample Date	Sample Date	Sample Date
	Oct 27, 2020	Mar 14, 2023	Apr 18, 2023	Nov 16, 2023
Contaminant	Result (ppt)	Result (ppt)	Result (ppt)	Result (ppt)
Perfluorooctanesulfonic acid (PFOS)	33	31	30	31
Perfluoroundecanoic acid (PFUnA)	ND	ND	ND	ND
Perfluorohexanoic acid (PFHxA)	8.2	8.1	7.7	8.7
Perfluorododecanoic acid (PFDoA)	ND	ND	ND	ND
Perfluorooctanoic acid (PFOA)	23	30	29	29
Perfluorodecanoic acid (PFDA)	ND	ND	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	15	14	14	15
Perfluorobutanesulfonic acid (PFBS)	6.8	7.1	6.4	7.6
Perfluoroheptanoic acid (PFHpA)	4.8	5.2	5.0	5.0
Perfluorononanoic acid (PFNA)	ND	ND	ND	ND
Perfluorotetradecanoic acid (PFTeDA) §	ND	ND	ND	ND
Perfluorotridecanoic acid (PFTrDA)	ND	ND	ND	ND

PFAS Sample Results from Midpoint for EP 102

**ND = Non-Detect, <2.0 ppt**

Important Note: Raw water sample collection will occur during the fourth quarter of 2024